

NORTHWESTERN ELECTRIC COOPERATIVE, INC.
POLICY NUMBER 109.0

- I. SUBJECT: Double-Throw Switches
- II. OBJECTIVE: To state the cooperative's policy on installation requirements of double-throw switches to comply with the National Electric Code for members using standby generators. NWECC reserves the right to inspect double-throw switches in conjunction with generators.
- III. POLICY: To ensure the safety of NWECC personnel, NWECC requires installation of a double-throw or transfer switch on all member locations that utilize a generator wired into the members existing service. The cost of the switch and any required material will be furnished by the member.
- The installation must comply with the National Electric Code. NWECC must be notified once installation is complete. NWECC reserves the right to disconnect service if deficiencies are found.
- IV. RESPONSIBILITY: Management

DATE ADOPTED: 01/23/85
DATE AMENDED: 05/26/93
DATE AMENDED: 05/27/98
DATE AMENDED: 05/26/04
DATE AMENDED: 01/26/11
DATE AMENDED: 10/24/12
DATE AMENDED: 04/26/17
DATE AMENDED: _____
REVIEW DATE: 07/27/22

Attested: _____



John R. Bruce, Jr., Secretary